

Maxxam Job #: B625821  
Report Date: 2016/04/08

City of Vancouver  
Client Project #: KITSILANO OUTDOOR POOL  
Site Location: ANNUAL MAINTENANCE, 2305 CORNWALL AVENUE, VANCOUVER  
Your P.O. #: 470002203  
Sampler Initials: RB

**LEAD IN PAINT CHIPS (PAINT)**

Maxxam ID		OK3060	OK3061	OK3062	OK3063	OK3064		
Sampling Date		2016/04/06	2016/04/06	2016/04/06	2016/04/06	2016/04/06		
COC Number		08419712	08419712	08419712	08419712	08419712		
	UNITS	KOP-L1 WHITE ON BLUE PAINT (POOL'S CONCRETE FLOOR - EAST SIDE)	KOP-L2 TEXTURED WHITE PAINT (POOL'S CONCRETE FLOOR - EAST SIDE)	KOP-L3 WHITE ON BLUE PAINT (POOL'S CONCRETE WALL - EAST SIDE)	KOP-L4 BLACK ON WHITE ON BLUE PAINT (POOL'S CONCRETE FLOOR - EAST SIDE)	KOP-L5 TEXTURED WHITE PAINT ( POOL'S CONCRETE FLOOR - MIDDLE SECTION)	RDL	QC Batch
<b>Total Metals by ICP</b>								
Total Lead (Pb)	mg/kg	22.9	<3.0	6.0	16.3	<3.0	3.0	8236246
RDL = Reportable Detection Limit								
Maxxam ID		OK3069	OK3070	OK3071	OK3072	OK3073		
Sampling Date		2016/04/06	2016/04/06	2016/04/06	2016/04/06	2016/04/06		
COC Number		08419713	08419713	08419713	08419713	08419713		
	UNITS	KOP-L6 WHITE ON BLUE PAINT (POOL'S CONCRETE FLOOR-MIDDLE SECTION)	KOP-L7 RED PAINT ON CONCRETE (POOL DECK SIGNAGE)	KOP-L8 YELLOW PAINT ON CONCRETE (POOL DECK SIGNAGE)	KOP-L9 WHITE ON BLUE PAINT (POOL'S CONCRETE WALL-WEST SIDE SIDE)	KOP-L10 WHITE ON BLUE PAINT (POOL'S CONCRETE FLOOR-WEST SIDE)	RDL	QC Batch
<b>Total Metals by ICP</b>								
Total Lead (Pb)	mg/kg	15.4	26.3	ND	24.4	30.9	3.0	8236246
RDL = Reportable Detection Limit								