

July 3, 2018

INVITATION TO TENDER "ITT" No. PS20180904

SUPPLY, INSTALLATION AND COMMISSIONING OF EXPO TUNNEL LIGHTING UPGRADE

AMENDMENT No. 1

1. RE: CLOSING DATE EXTENSION

*CURRENTLY READS:*

3:00 pm, Vancouver Time (as defined in Note 3 below), on Thursday, July 5, 2018 (the "Closing Time")

*REPLACE WITH:*

3:00 pm, Vancouver Time (as defined in Note 3 below), on Wednesday, July 11, 2018 (the "Closing Time")

2. RE: PART A, APPENDIX 2, Section 1.2 (c):

*A. CURRENTLY READS:*

- i. IP67 (16500 Tunnel Luminaires - Section: 1.06, D.);
- ii. MIL-A-8625F (16500 Tunnel Luminaires - Section: 1.07, J. 1. and 2.01, D.);
- iii. max. +50 degrees C (16500 Tunnel Luminaires - Section: 2.01, F.); and
- iv. Qualified manufacturers of LEDs include: NICHIA, CREE, OSRAM. (16500 Tunnel Luminaires - Section: 2.01, G.).

*B. REPLACE WITH:*

- i. IP66;
- ii. MIL-A-8625F and equivalent or greater;
- iii. max. +40 degrees C; and
- iv. Qualified manufacturers of LEDs include: NICHIA, CREE, OSRAM, SAMSUNG.

**All other conditions and specifications remain unchanged.**

---

INVITATION TO TENDER "ITT" No. PS20180904  
SUPPLY, INSTALLATION AND COMMISSIONING OF EXPO TUNNEL LIGHTING UPGRADE  
AMENDMENT No. 1

---

**This amendment must be completed, and attached to your Tender form.**

If you have already submitted your Tender, this amendment shall be submitted to the Purchasing Services Office, City of Vancouver, 453 West 12<sup>th</sup> Avenue, Vancouver, British Columbia, Canada, V5Y 1V4, (Courier Delivery and Drop off is at the Information Desk, Main Floor Rotunda of the same address), prior to the Closing Time: 3:00:00 pm Local Vancouver, BC Time, Wednesday, July 11, 2018 in an envelope clearly marked "AMENDMENT No. 1 to ITT, No. PS20180904 SUPPLY, INSTALLATION AND COMMISSIONING OF EXPO TUNNEL LIGHTING UPGRADE".

\_\_\_\_\_  
NAME OF VENDOR

\_\_\_\_\_  
SIGNATURE OF AUTHORIZED SIGNATORY

\_\_\_\_\_  
DATE

Peter Yung