

**REQUEST FOR PROPOSAL "RFP" NO. PS20170310
CONTRACTOR FOR TEMPORARY FIRE HALL 17**

QUESTIONS AND ANSWERS NO. 3

ISSUED ON JUNE 7, 2017

Q3.1	Are the primary sub-consultants Letters of Assurance limited only to Structural for both the Quarters and the Truck Shelter?
A3.1	Yes
Q3.2	Will the City of Vancouver be providing Letters of Assurance for both the Quarters and Truck Shelter for all other consulting disciplines including but not limited to the following: <ul style="list-style-type: none"> a. Architectural b. Geotechnical c. Building Code Consultants d. Mechanical and Electrical
A3.2	Architectural, Geotechnical, Code, Mechanical and Electrical Letters of Assurance have already been provided.
Q3.3	Do the Quarters exterior windows need to be fire rated in the north and east elevations?
A3.3	Rating only required on south wall as shown on drawings.