

REQUEST FOR QUOTATIONS "RFQ" NO. PS20172030
CONSTRUCTION SERVICES FOR BUILDING RENOVATIONS 342 ALEXANDER STREET

QUESTIONS AND ANSWERS NO. 1

ISSUED ON NOVEMBER 9, 2017

Q1	Looks like you are building a closet and restoring the stairwell on the main floor. it calls for electrical in closet, yet no mention of new panels. is this equipment already on site?
A1	There is no new panel onsite, if a new panel would be required by code, then please include this in your proposal
Q2	I just read through the specs for this project, it calls for Armstrong Stratamax which is a residential sheet vinyl. Could a commercial Armstrong or Tarkett product be used in place of the Stratamax?
A2	Please use an Armstrong Meditech or Medintone sheet good flooring product or equivalent