

REQUEST FOR QUOTATIONS NO. PS20180891

SUPPLY AND DELIVERY OF STEP UP KIOSKS

QUESTIONS AND ANSWERS NO. 1

ISSUED ON JUNE 18, 2018

Q1	How many kiosks are required?
A1	Six (6): all have to be custom-made, and the transformer inside must step up the voltage 240V to 240/480V.
Q2	Will the City accept stainless steel material with a brushed finish, unpainted?
A2	Unpainted kiosks are not acceptable to the City.
Q3	Is marine-grade aluminum with powder paint finish acceptable?
A4	Kiosks made of aluminum are not acceptable to the City.
Q5	Are alternates to Advance Protection SPD acceptable?
A5	Alternates are acceptable, if the technical characteristics are equal.
Q6	Is it acceptable to move the control circuit for the contractor control to the 120/240V panel?
A6	Not acceptable.