

INVITATION TO TENDER "ITT" PS20162024  
BURRARD MARINA UPLAND INFRASTRUCTURE

ADDENDUM NO. 3

April 7, 2017

1. SPECIFICATIONS: SECTION 26 00 00 - ELECTRICAL GENERAL REQUIREMENTS

Delete sub-section 3.8.2.1 in Section 26 00 00 of the Specifications and replace as follows:

- .1 As indicated on the Drawings, circuit breaker frames 400 Ampere and over shall have microprocessor-based RMS sensing trip units c/w adjustable Long, Short, Instantaneous, and Ground Fault protection. Continuous current ratings shall be adjustable from 40% to 100% of the trip unit rating, without the need for changing the rating plug. Circuit breaker frames 400A and larger and where indicated on the drawings shall be 100% equipment rated.

2. HAZARDOUS MATERIALS SURVEY

Delete the first three paragraphs in Section 2.0 of Schedule C and replace as follows:

A hazardous materials survey has been performed at the Site and is attached. No hazardous materials have been identified.

If, at any point during construction, the successful Tenderer encounters, or has reason to believe it will encounter, any hazardous materials, the successful Tender will be expected to immediately stop work and advise the City who will either decide to abate or will request the Tenderer do so by way of change order and the Tenderer will be required to use one of the City's pre-qualified hazardous material abatement contractors and/or consultants as set out below. Any abatement conducted by the Tenderer, through one of the City's pre-qualified hazardous material abatement contractors, must be completed in accordance with the Occupational Health and Safety Regulation and hazardous waste disposed of in accordance with the Environmental Management Act. A completion report including all disposal documentation must be provided to the City's Hazardous Materials Team upon project completion.

[End of page]

All other conditions and specifications remain unchanged.

This addendum must be completed and attached to the Tenderer's Tender.

If the Tenderer has already submitted its Tender, this addendum shall be submitted to the Supply Chain Management Office, City of Vancouver, 453 West 12<sup>th</sup> Avenue, Vancouver, British Columbia, Canada, V5Y 1V4, (courier delivery and drop off is at the drop box at the Supply Chain Management Office on the 4<sup>th</sup> Floor of the same address), prior to the Closing Time: 3:00 p.m. Vancouver Time, Tuesday, April 25, 2017 in an envelope clearly marked "Addendum No. 3 to ITT No. PS20162024: Burrard Marina Upland Infrastructure."

\_\_\_\_\_  
NAME OF VENDOR

\_\_\_\_\_  
SIGNATURE OF AUTHORIZED SIGNATORY

\_\_\_\_\_  
DATE