

July 20, 2018

**INVITATION TO TENDER "ITT" NO. PS20180885
MANITOBA YARDS WATER MAIN REPLACEMENT**

ADDENDUM NO. 1

**RE: PART A, B, C, ETC. - MANITOBA YARDS WATER MAIN REPLACEMENT
SUPPLEMENTAL SPECIFICATIONS AND DRAWINGS**

PLEASE ADD:

- 1. *Replace the drawing M201, M202, M203 dated June 14, 2018 with revised drawing M201, M202, M203 dated July 16, 2018***
- 2. *Clarification: It is anticipated that exterior water main replacement project will start 1st ahead of the other two projects: asphalt and concrete replacement project and this interior scope of work project. This interior scope of work project could start after or concurrently with exterior water main replacement project as long as it follows the proper sequence of work.***
- 3. *Clarification: Refer to the updated water main enclosure detail on M202. The enclosure will be equipped with an electric wall fan heater 1.5kW, 120/1/60 mounted 200 mm above finished elevation in the enclosure. The model # Ouellet OAC01502T or equal. This contractor is responsible for all electrical scope.***
- 4. *Clarification: This contractor shall apply for plumbing permit for this project.***
- 5. *Delete tree protection scope of work from this project.***

This addendum must be completed, and attached to your Tender form.

If you have already submitted your Tender, this addendum shall be submitted to the Purchasing Services Office, City of Vancouver, 453 West 12th Avenue, Vancouver, British Columbia, Canada, V5Y 1V4. Envelopes submitted by courier or otherwise in-person should be delivered to: Supply Chain Management

**453 West 12th Avenue, 4th Floor (Bid Submission Box) Vancouver City Hall
Vancouver, British Columbia, prior to the Closing Time: 3:00:00 pm Local
Vancouver, BC Time, in an envelope clearly marked "Addendum No. 1 to Invitation to
Tender No. PS20180885: MANITOBA YARDS WATER MAIN REPLACEMENT before the
closing time of 3:00 p.m., August 2, 2018.**

NAME OF VENDOR

SIGNATURE OF AUTHORIZED SIGNATORY

DATE

Gavin Marshall
Buyer II