

INVITATION TO TENDER "ITT" NO. PS20181106
CONSTRUCTION SERVICES FOR PRELOADING AT THE VANCOUVER LANDFILL

QUESTIONS AND ANSWERS NO. 1

ISSUED ON SEPTEMBER 21, 2018

Q1	We are looking to get an alternate product approval for one of the products mentioned in the above tender. The TX140 geogrid has been specified as part of the preload x-section and we would like approval to quote Egrid 2020 biaxial geogrid as a functional equivalent to this product. The TX140 is a patented product, so it is only available through one vendor in Canada. This would limit all contractors to have to buy from this one vendor. A biaxial geogrid performs the same function as a triaxial geogrid, which is base reinforcement
A1	<p>The section that it pertains to is Section 31 30 01 - 2.3 Geosynthetic Materials for the property requirements.</p> <p>Replace the word Triaxial to Biaxial in the following sections of the Specifications and Drawings:</p> <ul style="list-style-type: none"> • Section 31 20 01 - 1.2 Definition • Section 31 20 01 - 2.3 Geosynthetic Materials • Drawing TLO168 - Notes section • Drawing TL0169