

**INVITATION TO TENDER “ITT” No. PS20181253
SUPPLY AND INSTALL OUTDOOR FITNESS EQUIPMENT
AT MEMORIAL SOUTH PARK**

QUESTIONS AND ANSWERS NO. 3

ISSUED ON September 12, 2018

Q3.1	Does item 3.1 require a soil component and if so to what depth?
A3.1	Requirements for the areas to receive sod are outlined in the associated specification, 32 92 23 Sod Lawn. There is not a requirement to import/install growing medium at areas of existing turf that need to be restored after construction, assuming the original soil is still present.