

August 27, 2018

INVITATION TO TENDER "ITT" NO. PS20181272
GENERAL CONTRACTOR FOR CONSTRUCTION OF SMITHE AND RICHARDS PARK

ADDENDUM NO. 2

All attachments listed herein are incorporated by reference and can be downloaded from the City's FTP site with log on details provided to the pre-qualified Tenderers.

RE: PART A - APPENDIX 3 - SPECIFICATIONS

SECTION 05 05 19 - COMMON WORK RESULTS FOR METALWORK FINISHING

2.3.1.2 Shop Finishing; Exposed Standard Structural Steel

CURRENTLY READS:

- Zone 1A: Shop prime using CISC/CPMA 2-75 over minimum SSPC- SP6 ready for site applied finish coat specified in Section 09 91 00.

REPLACE WITH:

- Zone 1A: Minimum SSPC SP6 ready for site applied finish coat specified in Section 09 91 00

2.3.1.3 Shop Finishing; Exposed Standard Structural Steel

CURRENTLY READS:

- Zone 2B: Shop prime using Inorganic Zinc Primer over minimum SSPC-SP10 ready for high build coating of FEVE and aliphatic isocyanate.

REPLACE WITH:

- Zone 2B: Shop prime using Inorganic Zinc Primer over minimum SSPC SP16 ready for high build coating of FEVE and aliphatic isocyanate.

2.3.5 *DELETE:*

- Refer to Section 09 91 00 for coating and application requirements for application of site applied finishing systems.

SECTION 07 14 00 - FLUID APPLIED WATERPROOFING

3.2.1 Shop Finishing; Exposed Standard Structural Steel

CURRENTLY READS:

- This Section includes requirements for supply and installation of a fluid applied elastomeric waterproofing membranes including surface preparation and accessories required for a complete system for the tanks.

REPLACE WITH:

- This Section includes requirements for supply and installation of a fluid applied elastomeric waterproofing membranes including surface preparation and accessories required for a complete system.

SECTION 32 37 00 - EXTERIOR SITE FURNISHINGS

2.1 Materials

ADD:

- .8 Tamperproof Swivel Eye Bolt: Tamper Resistant, Stainless Steel, 3/8-16 Thread, Load
 - .1 Basis-of-Design Material: Essentra Components, SHR-47631

RE: PART A - APPENDIX 3 - DRAWINGS

A211 - UPPER GROUND PLAN CAFÉ PAVILION

- *REPLACE* Drawing A211 with attached Drawing A211 - REVISED
 - Detail A811-1 Refers to wall assembly along GL CX

A224 - ENLARGED PLANS; and

A226 - ENLARGED PLANS

- *REPLACE* Drawings A224 and A226 with attached Drawings A224 - REVISED and A226 - REVISED
 - **Plan details for hammock**

A521 - SECTIONS

- *REPLACE* Drawing A521 with attached Drawing A521 - REVISED
 - Section details colour

A523 - SECTIONS

- *REPLACE* Drawing A523 with attached Drawing A523 - REVISED
 - Add note

A524 - SECTIONS

- *REPLACE* Drawing A524 with attached Drawing A524 - REVISED
 - Add note and revised stringer support

A810 - WALL SECTIONS 01 CAFÉ PAVILION

- *REPLACE* Drawing A810 with attached Drawing A810 - REVISED
 - Section detail 2/A810 note

S0.02 - GENERAL NOTES

ADD:

1. DRAWING S0.02 - GENERAL NO STRUCTURAL STEEL note 1.6 to read as follows:

1.6 Structural Steel

CURRENTLY READS:

- REFER TO SPECIFICATIONS SECTION 05 51 00 FOR REQUIREMENTS FOR STAIRS, LADDERS, HANDRAILS, AND PLATFORMS NOT DETAILED ON THE STRUCTURAL DRAWINGS.

REPLACE WITH:

- REFER TO SPECIFICATIONS SECTIONS 05 05 00 AND 05 50 00 FOR REQUIREMENTS FOR STAIRS AND HANDRAILS NOT DETAILED ON THE STRUCTURAL DRAWINGS.

L2.01 - MATERIALS PLAN

- *REPLACE* Drawing L2.01 with Drawing L2.01 - REVISED (Aug 22 2018)
 - Revised; scuppers

L2.01 - MATERIALS PLAN; and L9.40 - STAIRS AND SEAT STEPS DETAILS SHEET 1

- *REPLACE* Drawings L2.01 and L9.40 with attached Drawings L2.01 REVISED (Aug 22, 2018) and L9.40 - REVISED
 - Edger detail has been modified. The edger is also three sides of the planter

L9.31 - WOOD DECKING AND SEAT TOP DETAILS SHEET 2; and L9.32 - WOOD DECKING AND SEAT TOP DETAILS SHEET 3

- *REPLACE* Drawings L9.31 and L9.32 with attached Drawings L9.31 - REVISED and L9.32 - REVISED
 - Revised Bench details

L9.40 - STAIRS AND SEAT STEPS DETAILS SHEET 1

- *REPLACE* Drawing 9.40 with attached Drawing L9.40 - REVISED
 - Section detail 6/9.40

L9.51 - SITE FURNISHING DETAILS SHEET 2

- *REPLACE* Drawing L9.51 with attached Drawing L9.51 - REVISED
 - Revised detail

L9.52 - SITE FURNISHING DETAILS CHILDRENS PLAY AREA PLAN

- *REPLACE* Drawing L9.52 with attached Drawing L9.52 - REVISED
 - Colours of spheres added

This addendum must be completed, and attached to your Tender form.

If you have already submitted your Tender, this addendum shall be submitted to the Purchasing Services Office, City of Vancouver, 453 West 12th Avenue, Vancouver, British Columbia, Canada, V5Y 1V4, (Courier Delivery and Drop off is at the Information Desk, Main Floor Rotunda of the same address), prior to the Closing Time: 3:00:00 pm Local Vancouver, BC Time, September 18, 2018 in an envelope clearly marked "Addendum No. 1 to Invitation to Tender No. PS20181272: General Contractor for Construction of Smithe and Richards Park before the closing time of 3:00 p.m., September 18, 2018.

NAME OF VENDOR

SIGNATURE OF AUTHORIZED SIGNATORY

DATE

Jessica Li
Buyer