
INVITATION TO TENDER "ITT" No. PS20191127
PNE HASTINGS ROOM RE-ROOFING

ADDENDUM No. 1

August 29, 2019

1. Re: Revised Specifications: Section 01 11 00 - Summary of Work

Section 1.8.1.2.4 (Low Slope Membrane Roofing) has been revised as follows:

DELETE Section 1.8.1.2.4 from the Specifications and REPLACE as follows:

4. On Roof Areas 3.2 and 3.3 - See Roof Plan R1 for skylights to be converted to exhaust fans and vent stacks to be deleted and roofed over.
 - .1 New Roof Exhaust Fan #1 to be installed on Roof Area 3.2:
 - .1 Greenheck, Model: G-90 - 1/12HP with gravity backdraft damper. 600 cfm at .25 inches WC. Complete with interior switch. Confirm available voltage, select fan suitable for this voltage. Adapt roof curb to suit exhaust fan. Confirm specified fan air delivery after installation.
 - .2 New Roof Exhaust Fan #2 to be installed on Roof Area 3.3:
 - .1 Greenheck, Model: G-123 - VG1/2 - A1/2 with gravity backdraft damper. 1,500 cfm at .25 inches WC. Complete with interior switch. Confirm available voltage, select fan suitable for this voltage. Adapt roof curb to suit exhaust fan. Confirm specified fan air delivery after installation.
 - .3 The contractor is responsible for all required electrical work and interior finishes related to the installation.

[End of page]

All other conditions and specifications remain unchanged.

This addendum must be completed and attached to the Tenderer's Form of Tender.

If the Tenderer has already submitted its Tender, then this addendum shall be submitted by email to the Contact Person identified in the ITT with the subject line "ADDENDUM No. 1 to ITT No. PS20191127 - PNE Hastings Room Re-Roofing" before the Closing Time of 3:00:00 p.m., Vancouver Time, on September 3, 2019.

NAME OF VENDOR

SIGNATURE OF AUTHORIZED SIGNATORY

DATE