

INVITATION TO TENDER "ITT" PS20201112

CONTRACTOR FOR ANDERSON STREET UTILITY UPGRADE

QUESTIONS AND ANSWERS NO. 3

ISSUED ON NOVEMBER 17, 2020

Q1	<p>Good afternoon, can the following aggregate materials be acceptable to use in this project?</p> <ul style="list-style-type: none"> • 19mm Minus (3/4") - Cov #9 • Fraser River Sand (MMCD River Sand) <p>City of Vancouver Specs is hard to meet by our suppliers, they could only come close to the requirements but they are widely used in the lower mainland in particular.</p>
A1	<p>19mm Minus (3/4") – Cov #9 is Acceptable.</p> <p>Fraser River Sand (MMCD River Sand) is acceptable for pipe bedding and surround</p>
Clarification	<p>Please take note below.</p>
	<p>Discharge of Trench Dewatering to Sewers:</p> <p>As a general rule, water should be treated to meet the requirements of the Sewer and Watercourse By-Law such that it can be discharged to the storm sewer.</p> <p>In the event contractors are unable to adequately treat contaminants in the water, contractors can potentially discharge to the Sanitary Sewer. Contractors shall obtain a discharge permit to do so.</p>