

INVITATION TO TENDER NO. PS20210225

CONTRACTOR FOR WATER MAIN TRENCHLESS CROSSING ALBERNI @ BUTE STREET

QUESTIONS AND ANSWERS NO. 1

ISSUED ON MAY 14, 2021

Q1	<p>With reference to the above Tender call, our trenchless equipment is limited to use under the sizes outlined in the table below:</p> <table><tr><td>ITEM</td><td>Tender size</td><td>Proposed size (approx.)</td></tr><tr><td>Carrier steel pipe</td><td>900 mm</td><td>1200 mm (48 inch)-minimum</td></tr><tr><td>Entrance Pit</td><td>8m*4m*5.4m</td><td>15m*5m*6m</td></tr><tr><td>Exit Pit</td><td>4m*3m*3.1m</td><td>10m*5m*3.5m</td></tr></table> <p>The equipment that we would use is the similar that was used to bore the trenchless crossing Contract (PS 20151724) under Burrard Street in 2016. Could you please advise if the proposed sizing can be allowed to be included under this Tender in order to enable us to provide the City with a Proposal?</p>	ITEM	Tender size	Proposed size (approx.)	Carrier steel pipe	900 mm	1200 mm (48 inch)-minimum	Entrance Pit	8m*4m*5.4m	15m*5m*6m	Exit Pit	4m*3m*3.1m	10m*5m*3.5m
ITEM	Tender size	Proposed size (approx.)											
Carrier steel pipe	900 mm	1200 mm (48 inch)-minimum											
Entrance Pit	8m*4m*5.4m	15m*5m*6m											
Exit Pit	4m*3m*3.1m	10m*5m*3.5m											
A1	<p>The proposed sizing cannot be accommodated due to constraints of the site condition.</p>												