

DATE April 27, 2022

INVITATION TO TENDER NO. PS20220548

CONTRACTOR FOR BRITANNIA ARENA CONDENSER REPLACEMENT

AMENDMENT NO. 1

RE: ADDITIONAL INFORMATION DETAILS TO BE INCLUDED AS PART OF THE SCOPE OF WORK

- 1) The Specifications include the following for the DDC system upgrade. They shall be included in the scope:
 - Retain and reconnect the existing DDC control of the condenser and water pump operation.
 - The existing DDC system shall be reviewed. Necessary upgrade such as the compressor lead/lag switch over and the compressor safety shut-down shall be included in the work scope.

- 2) The existing ventilation air proving switch replacement & ventilation failure alarm upgrade shall be included in the scope:
 - Replace the existing fresh air intake air proving sail switch with a damper position switch (Kele TS (1) -475 SPDT non-mercury or approved equivalent).
 - Replace the two existing exhaust sail switches with an air proving switch (White-Rogers type 770-1 SPDT dual purpose or approved equivalent)
 - Supply and install necessary field wiring and electrical components to connect the new switches with the DDC system.
 - Provide necessary DDC software upgrade to provide the ventilation failure alarm.

NAME OF VENDOR

SIGNATURE OF AUTHORIZED SIGNATORY

DATE

Jason Lo
Contracting Specialist