

May 30, 2018

REQUEST FOR PROPOSAL "RFP" PS20180799
SUPPLY AND DELIVERY OF PIPE AND FITTINGS

AMENDMENT No. 2

RE: SECTION 1.1 (b) (iii) OF PART B, RFP

CURRENTLY READS:

- (iii) Waterworks service saddles ("Requirement C") to support the daily maintenance, repair and operation functions of the City. The service saddles should be designed to provide a drip-tight connection when used as a service connection to the watermain. The body of the service saddles should be made to conform to the outside configuration of the watermain. The materials used to produce the service saddle body should be ductile iron and should conform to the latest edition of the ASTM Standard Specifications for Ductile Iron Castings, designation A536, grade 65-45-12. The City requires, without limitation, the following:
1. (4; 6; 8; 12") x 1-1/2" C.C. threads and I.P. threads;
 2. (4; 6; 8; 12")"x 2" C.C. threads and I.P. threads; and
 3. 18" x 1 1/2" C.C. threads.

REPLACE WITH:

- (iii) Waterworks service saddles ("Requirement C") to support the daily maintenance, repair and operation functions of the City. The service saddles should be designed to provide a drip-tight connection when used as a service connection to the watermain. The body of the service saddles should be made to conform to the outside configuration of the watermain. The materials used to produce the service saddle body should be ductile iron and should conform to the latest edition of the ASTM Standard Specifications for Ductile Iron Castings, designation A536, grade 65-45-12. **Gaskets shall be made of nitrile type (Acrylonitrile Butadiene, NBR) material to resist oil, natural gas, acids, alkaline, hydrocarbon fluid and water. Rubber (SBR) gaskets will not be accepted.** The City requires, without limitation, the following:
4. (4; 6; 8; 12") x 1-1/2" C.C. threads and I.P. threads;
 5. (4; 6; 8; 12")"x 2" C.C. threads and I.P. threads; and
 6. 18" x 1 1/2" C.C. threads.

All other conditions and specifications remain unchanged.

This amendment must be completed, and attached to your Proposal form PART C.

NAME OF VENDOR

SIGNATURE OF AUTHORIZED SIGNATORY

DATE

Jing Fan/Buyer