

REQUEST FOR PROPOSAL “RFP” PS20210877

SUPPLY AND DELIVERY OF CONCRETE POLE ADAPTERS AND POST TOP LED

QUESTIONS AND ANSWERS NO.2

ISSUED ON August 23, 2021

Q1	Does Full Cutoff mean U0 from the BUG rating?
A1	Yes, full cut off is to be specified as U0 BUG rating.
Q2	Can we offer multiple types for each style? What is the maximum?
A2	You may offer two types for each style. Each type should be submitted as part of separate proposal packages. Eg. Type 1 FCO, Type 1 Non-FCO as one package. Type 2 FCO, Type 2 Non-FCO as part of a second package. The recommended approach, if you choose to submit 2 styles, is to submit your best luminaire, and your most economical for each application.
Q3	For the ITRON system, are you only asking to have a P7 receptacle to facilitate this connection?
A3	The P7 receptacle and casting/housing of the luminaire must be capable of supporting the installation of a control node that will be used to connect the luminaire to the ITRON control system. The minimum clearance of the casting must accommodate a control node of a diameter that is consistent with the standard diameter of a P7 receptacle and of a height that is at least 3.15 inches.
Q4	Can you please provide a photo of the existing capital shown on detail 1 of drawing no. LDS-1.2. on page 18 of RFP document.

A4



The attached photo is of the top part of an existing concrete post top piece that was removed from use. The adapter should fit and be secured into this piece, and provide a tenon adaptation for the new LED post top acorn luminaires.