

REQUEST FOR PROPOSAL "RFP" NO. PS20181470
CONSULTANT SERVICES - PRV CONDITION ASSESMENTS

QUESTIONS AND ANSWERS NO. 1

ISSUED ON: September 20, 2018

Q1	Can you advise what the City's budget is for the work?
A1	Typically, the City does not provide budgetary information when an RFP is posted publically.
Q2	What is the proposed scope for assessing the piping and PRV valve condition? I.e. a visual assessment vs non-destructive testing.
A2	<p>A visual assessment based on sound principles should be used for the condition assessments. The 5-point condition rating scale as provided in Part B - City Requirements is to be applied to the assessment.</p> <p>If a viable non-destructive testing method exists, proponents may propose as an alternative for the City's consideration.</p>