

INVITATION TO TENDER "ITT" NO. PS20190793
GRANVILLE RESIDENCE ELEVATOR AND FIRE PANEL CONSTRUCTION

QUESTIONS AND ANSWERS NO. 1

ISSUED ON AUGUST 22, 2019

Q1	The existing fire alarm wiring that runs back to the fire alarm panel is run free air. Please clarify if the electrical contractor is required to install this cable in conduit in the room that the panel is located.
A1	Yes, the wiring shall be in conduit per our specifications.